

TEST REPORT

TO: Alsea School District
PO Box B
Alsea, OR 97324

03/01/2024

ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-004
Location: 1st Grade

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	02/21/2024	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Alesa School District
PO Box B
Alesa, OR 97324

03/01/2024
ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-005
Location: 2nd Grade

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	5.01		1	ppb	15	02/21/2024	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Alsea School District
PO Box B
Alsea, OR 97324

03/01/2024
ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-006
Location: SW Modular fountain

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	1.97		1	ppb	15	02/21/2024	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Alsea School District
PO Box B
Alsea, OR 97324

03/01/2024
ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-007
Location: SW Modular kitchen

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	02/21/2024	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Alsea School District
PO Box B
Alsea, OR 97324

03/01/2024
ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-008
Location: SW Modular sink

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	1.35		1	ppb	15	02/21/2024	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Alsea School District
PO Box B
Alsea, OR 97324

03/01/2024
ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-009
Location: 3rd grade

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	33.0		1	ppb	15	02/21/2024	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Alsea School District
PO Box B
Alsea, OR 97324

03/01/2024

ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-010
Location: kindergarden

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	02/21/2024	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Alsea School District
PO Box B
Alsea, OR 97324

03/01/2024
ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-011
Location: Staff Room

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	16.2		1	ppb	15	02/21/2024	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Alsea School District
PO Box B
Alsea, OR 97324

03/01/2024

ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-012
Location: NW Modular

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	2.33		1	ppb	15	02/13/2024	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Alsea School District
PO Box B
Alsea, OR 97324

03/01/2024
ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-013
Location: Elementary Hall Fountain

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	02/21/2024	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Alesia School District
PO Box B
Alesia, OR 97324

03/01/2024
ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-014
Location: MS Hallway Fountain

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	02/21/2024	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Alsea School District
PO Box B
Alsea, OR 97324

03/01/2024
ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-015
Location: 5th Grade

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	02/21/2024	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

TO: Alsea School District
PO Box B
Alsea, OR 97324

03/01/2024

ALSSCH

PO#:

Collection Information

Date: 02/05/2024
Time: 0600
By: Keenan
Lab #: 20240206-016
Location: 6th Grade

Lab Receipt Information

02/06/2024
1000
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	2.92		1	ppb	15	02/21/2024	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____

